

August 1947 Edition

RULES AND REGULATIONS FOR THE
CONSTRUCTION, ALTERATION, REPAIR AND CONVERSION OF
BUILDINGS FOR RESIDENTIAL PURPOSES

Specifically -

for single family residences, not over 2 stories and an attic in height;

for duplex houses (two units side by side), row houses, and two, three and four family apartments or flats, not over 2 stories in height;

for buildings customarily accessory to the foregoing; and

for any residential portions of office, store and other business buildings, not higher than the second floor, subject to such additional requirements as may apply to such buildings.

These rules and regulations set forth requirements which are considered reasonable and are held in every instance to be minimum for the promotion of the public health, safety and general welfare.

Printed by the
SUBURBAN BUILDING OFFICIALS CONFERENCE
79 W. Monroe St., Room 1019
Chicago 3

Telephone Central 1034

CONTENTSMINIMUM PLANNING REQUIREMENTS

- 200 LIGHT AND VENTILATION
 - A General
 - B Habitable Rooms
 - C Alcoves
 - D Bathrooms and Water Closet Compartments
 - E Open Basements
 - F Laundries and Recreation Rooms
 - G Utility Rooms
 - H Heater Rooms
 - I Basementless Spaces
 - J Attics and Air Space
- 201 SPACE REQUIREMENTS
 - A Living Unit
 - B Additional Habitable Rooms
 - C Bedroom Closets
 - D Storage Space
 - E Space for Heating Units
- 202 HABITABLE BASEMENT ROOMS
 - A Comply With Requirements for Main Floor Rooms
 - B Floor
 - C Areaways
- 203 PORCHES AND TERRACES
 - A Dimension
 - B Guard rails
 - C Exterior Steps
- 204 PRIVACY AND ACCESS
 - A Access
 - B Privacy
- 205 CEILING HEIGHTS
 - Ceiling Heights
- 206 DOORS
 - A Exterior Doors
 - B Interior Doors
- 207 STAIRWAYS
- 208 SCREENS
- 209 FLOOR AREAS AND FIRE WALLS
- 210 MINIMUM WIDTH OF ROW DWELLINGS
- 211 FIRE LIMITS

MINIMUM CONSTRUCTION REQUIREMENTS

- 300 GENERAL
 - A Construction Materials and Methods
 - B Loads
 - C Special Conditions and Tests
 - D Vapor Barriers
 - E Sound Transmission

- 301 EXCAVATION
 - A Foundations, Trench Walls and Piers
 - B Basementless Spaces
- 302 GRADING
 - A Backfill
 - B Grading
- 303 MASONRY MATERIALS
 - A Cement
 - B Aggregate
 - C Water
 - D Lime
 - E Brick
 - F Structural Hollow Clay Tile
 - G Concrete Masonry Unit
 - H Stone
 - I Flue Lining
 - J Glass Block
- 304 CONCRETE WORK
 - A General
 - B Plain Concrete
 - C Reinforced Concrete
 - D Forms
 - E Placing
 - F Protection
 - G Loading
 - H Footings
 - I Footing Drain Tile
 - J Concrete Foundation Walls Cast in Place
 - K Concrete Floor Slabs on Ground
 - L Exterior Wood Stairs
 - M Reinforced Concrete Floor on Precast Joists.
- 305 MASONRY WORK
 - A General
 - B Masonry Unit Foundation Walls
 - C Dampproofing and Waterproofing
 - D Piers
 - E Exterior Masonry Walls Above Grade
 - F Masonry Veneer
 - G Cavity Walls
 - H Interior Masonry Walls
 - I Chimneys
 - J Fireplaces
 - K Glass Block
- 306 STRUCTURAL STEEL AND IRON
 - A General
 - B Beams and Girders
 - C Columns
- 307 WOOD CONSTRUCTION
 - A Lumber
 - B Framing, General
 - C Floor Framing
 - D Ceiling Framing
 - E Roof Framing
 - F Exterior Wall and Bearing Partition Framing

- G Non bearing Partition Framing
- H Wall Sheathing
- I Sheathing Paper
- J Roof Sheathing
- K Stair Stringers
- L Caulking
- 309 EXTERIOR WALL FINISH
 - A Wood siding
 - B Wood Shingle Siding
 - C Asbestos-Cement Siding and Shingles
 - D Plywood
 - E Stucco
- 310 ROOF COVERINGS
 - A General
 - B Asphalt Shingles
 - C Wood Shingles
 - D Asbestos Cement Shingles
 - E Tile Roofing
 - F Slate shingles
 - G Built-up Roofs
 - H Metal Roofs
 - I Other types of Roof Coverings
- 311 FLASHING
 - A Material
 - B Openings not Protected by Overhang
 - C Intersections
 - D Valleys
 - E Roof and Wall Intersections
 - F Terrace or Porch Slabs
 - G Chimneys
- 312 GUTTERS AND DOWNSPOUTS
 - A Materials
 - B Basket Strainers
 - C Roof Water Disposal
- 313 INTERIOR WALL AND CEILING FINISH
 - A Lath and Plaster
 - B Ceramic Tile
 - C Shower Wall
 - D Dry Wall Finish
 - E Heater Room Interior Finish
- 314 FINISH FLOORS
 - A Cement Floors
 - B Wood Floors
 - C Ceramic Tile
 - D Rubber Tile, Asphalt Tile and Linoleum
- 315 GARAGES
 - A Attached and Built-in Garages
 - B One-story Detached Garages

MINIMUM PLANNING REQUIREMENTS

200 LIGHT AND VENTILATION

A General

- 1 Install windows in outside walls to provide natural light and ventilation in all habitable rooms.
- 2 Windows in habitable rooms, whose areas provide the light and ventilation necessary to comply with the following requirements are considered required windows. All windows in addition to these, and also windows in rooms other than habitable rooms, are considered nonrequired windows.
- 3 The area of glazed portions of doors located in exterior walls may be included when necessary in determining compliance with the following requirements:

B Habitable Rooms: Rooms designed to be used for living, sleeping, eating or cooking.

- 1 Required windows in each habitable room:
 - a Total glass area: Not less than 10 per cent of floor area of room.
 - b Ventilating area: Not less than 5 percent of floor area of room.
 - c Under covered porches: Increase glass area to not less than 15 percent and ventilating area to not less than 6 percent of floor area of room.

C Alcoves

- 1 Unless separately lighted and ventilated by windows which provide the required window area, include any alcove adjoining a habitable room as part of that room in computing required window area.
- 2 The common wall between the alcove and the habitable room shall contain an opening, the area of which shall be not less than 80 percent of the area of the entire wall on the alcove side.

D Bathrooms and Water Closet Compartments

Provide ventilation by one of the following means:

- 1 Window or skylight:
 - a Locate window in an exterior wall.
 - b Glass area for bathrooms only, minimum 10% of floor area; not less than 3 sq. ft.
 - c Ventilating area, minimum 5% of floor area.
- 2 Vent in or near ceiling with continuous duct connection to outside air.
 - a Gravity exhaust, connect to louvered roof vent, minimum duct dimension, 3-1/2 inches, minimum area, 48 square inches.
 - b Mechanical exhaust, 1 complete air change each 10 minutes.

E Open Basements.

Provide light and ventilation by windows or doors, in exterior walls with both glazed and ventilating area not less than 2 percent of the floor area.

F Laundries and Recreation Rooms.

Provide light and ventilation by windows or glazed doors, in exterior walls:

1. When located in a separately enclosed space in the basement, the glazed and ventilating area shall be not less than 5 percent of floor area.
2. When located above basement level, glazed area shall not be less than 12 percent of floor area, ventilating area not less than 5 percent of floor area.

G Utility Rooms.

Ventilate utility rooms other than a laundry room by:

- 1 Windows or doors, in exterior walls with ventilating area not less than 2 percent of floor area; or
- 2 Duct or ducts, minimum total free area 2 percent of floor area.

H Heater Rooms.

Provide fixed ventilation to any confined space which encloses heating equipment, by means of a duct arranged to supply air from outside. Duct to be screened and to have free area at least equal to free area of flues or vents to which the equipment is connected.

I Basementless Spaces.

- 1 Provide a sufficient number of foundation wall vents to assure a total ventilating area equivalent to 1 square foot for each 15 lineal feet of exterior wall.
- 2 Number of vents; minimum 2.
- 3 Locate vents to provide cross-ventilation wherever possible.
- 4 No vents required for basementless spaces, one side of which, exclusive of structural supports such as piers, chimney foundations, etc., is open to a ventilated basement, provided the total area of ventilating openings is 2 percent of the basement area plus the area of the basementless space.
- 5 In each vent opening install corrosion-resistant screening, mesh not less than 8 per inch.

J Attics and air space between ceiling and flat roofs.

- 1 Provide effective fixed ventilation in all spaces between roofs and top floor ceilings, by replaceable or nonferrous screened louvres, 16 mesh.
- 2 Net ventilation area for each separate space to be not less than 1/300 of area of house at top plate. Where possible, locate vents to provide effective cross-ventilation.

201 SPACE REQUIREMENTS

A Living Unit. Provide at least one bedroom and one bathroom, and space for living, dining, cooking, storage, utility and heating, as follows:

- | | <u>Min. Area</u>
<u>Square ft.</u> |
|---|---------------------------------------|
| 1 Living, dining, cooking. | |
| a Living, dining and cooking when in one room (includes area occupied by equipment) | 220 |
| b Living, dining, when in one room | 180 |
| c Living only in one room, when dining space is provided in kitchen or separate room | 160 |
| d Kitchen, cooking only (including area occupied by equipment) | 60 |
| Provide at least 30 square feet additional area, usable for dining purposes when dining space is included in the kitchen. | |
| 2 Sleeping: | |
| a Major bedroom | 100 |
| 3 Bathroom: | |
| Size: Adequate for water closet, lavatory, and tub or shower. The water closet may be located in a separate compartment adjoining the bathroom. | |

- B Additional Habitable Rooms. See 200-B
- 1 Minimum floor area 80 square feet.
- C Bedroom Closets.
- 1 Provide each bedroom with at least one closet or wardrobe having a minimum:
 - a Depth: 1 foot 10 inches.
 - b Floor area: 5 square feet.
 - c Height: 6 feet.
- D Storage Space
- 1 Minimum volume: 600 cubic feet, each living unit, in addition to minimum bedroom closets.
 - 2 Height: Space less than 4 feet in clear height will not be considered as providing storage space under these requirements.
 - 3 Location: Closets, utility room, attic, basement or attached garage. Closets which are in addition to bedroom closets, and the portion of bedroom closets in excess of 5 square feet per bedroom, may be included as storage space. That portion of utility or heater rooms which is necessary for equipment, passage and work space, may not be included as storage space. Portions of attached garage, in addition to the area for vehicle storage, may be considered as storage space if separately enclosed and fitted with a door.
 - 4 Adequate fuel storage space to be provided in addition to above.
- E Space for Heating Units.
- 1 Provide space within the building for heating unit or system.
 - 2 Provide clearances for maintenance and repair.
 - 3 Provide clearances for fire safety, determined by insulation of heater and combustibility of walls, floor, and ceiling. Heat generated shall not raise the surface temperature of combustible walls, floor or ceiling above 160°F.

202 HABITABLE BASEMENT ROOMS

- A Comply with requirements for main floor rooms with respect to privacy, light and ventilation, floor area, ceiling height, etc.
- B Finish floor below the adjoining outside finish grade: Maximum, 2'-6" at required windows.
- C Areaways: Minimum width measured perpendicular to face of building wall, 2 feet. Increased 1 inch for every inch of depth over 2 feet. Head of window, in all cases, to be at or above top of areawall.

203 PORCHES AND TERRACES

- A Minimum dimension from face of building where there are more than two risers between grade and first floor, 4 feet.
- B Guard rails to be provided:
- 1 When more than 24 inches above grade and center line of exterior door is on center line of steps.
 - 2 When more than 16 inches above grade and center line of door is not on center line of stairs.
- C Provide guardrails on exterior steps of more than 4 risers to porches or terraces above grade.

204 PRIVACY AND ACCESS**A Access**

- 1 Living units. Each living unit shall be provided with two means of access without passing through any other living unit.
- 2 Attics. Provide access to attics by means of scuttles, disappearing or built-in stairways.
- 3 Basementless spaces. Provide access not less than 18" by 24".
- 4 Basements. Provide direct access to outside at grade by a door, or a window having an openable area at least 2 feet wide and 30 inches high, stool not more than 3 feet above floor.

B Privacy**1 General:**

- a Locate exterior openings in relation to exterior conditions including existing or possible future adjacent buildings or other living units.
 - b Give consideration to the interior arrangement of rooms, particularly with respect to bedrooms, bathrooms, and toilet compartments.
- 2 Bedroom privacy:**
- a At least two bedrooms to have access to a bathroom without passing through another habitable room.
 - b Each bedroom to have access to a bathroom without passing through another bedroom.
 - c Each habitable room to have access to each other habitable room without passing through a bedroom.
- 3 Nonacceptable bathroom arrangements:**
- a Sole bathroom opening directly into a kitchen.
 - b Bathroom providing sole access to any other room.
 - c Bathroom in the basement as the only one serving a living unit.

205 CEILING HEIGHTS**A Minimum Ceiling Heights.**

- 1 Basements: 7'-0" clear under joists. See 202-A
- 2 Main floor of any living unit: 8'-0" clear for at least 75% of the floor area.
- 3 Second story of any living unit: 7'-6" clear; under sloping roofs, 7'-6" for not less than 50 percent of floor area having 5 feet or more headroom.

206 DOORS**A Exterior Doors.**

- 1 Minimum sizes:
 - a Main entrance doors: 2'-10" wide.
 - b Service entrance doors: 2'-8" wide.
 - c Height: 6'-8".

B Interior Doors

- 1 Provide a door for each opening to a bedroom, bathroom, and toilet compartment.
- 2 Minimum sizes:
 - a All habitable rooms: 2'-4" wide by 6'-6" high
 - b Bathrooms: 2 feet wide.

207 STAIRWAYS - See 307-K

A Design and Location:

Provide for safety of ascent and descent; install proper artificial light in addition to any natural light; and provide an easy run by proper proportioning of tread width to riser height.

- 1 Headroom: Continuous clear headroom measured vertically from front edge of tread to a line parallel with stair run, minimum 6'-6".
- 2 Width:
 - a Main stairs: Minimum, 2'-9" clear of handrail.
 - b Basement stairs: Minimum, 2'-6" clear of handrail.
- 3 Treads: Minimum width, 9 inches, with nosing, 10-1/4.
- 4 Rise: 8 inches maximum. All riser heights to be same in any one story.
- 5 Winders: tread width 18 inches from converging end shall at least equal tread width on straight stair run unless width of tread at converging end is 6 inches or more.
- 6 Landings: Width equal to that of stair.
- 7 Handrail: Install continuous handrail on at least one side of each run on each stair and on stair well.

208 SCREENS

Install on all exterior doors and windows used for ventilation, including basement windows, at least 16 mesh.

209 FLOOR AREAS AND FIRE WALLS

Provide 8 inch masonry wall without an opening between living units of duplexes and row houses and between tiers of living units of other multiple family dwellings. See also 300-E

210 MINIMUM WIDTH

The width of any row or duplex dwelling measured between the interior finished surfaces of party walls or end walls shall be not less than 15 feet.

211 FIRE LIMITS

Within the fire limits residential buildings shall comply with the requirements of ordinances relating to construction within such limits.

MINIMUM CONSTRUCTION REQUIREMENTS

300 GENERAL

A Construction Materials and Methods.

These requirements specify minimum acceptable construction materials and methods. Other materials and methods not specified herein may be approved for use by the Building Official upon the submission of evidence satisfactory to him that their performance in use will be at least equivalent to that of the materials and methods specified herein. It may be required that such evidence include adequate reports and test data from a recognized testing laboratory, or proven and authoritative service records, or analysis of performance made in accordance with well established principles of mechanics. Compliance with the standard specifications and test methods listed in Appendix A will be required.

B Loads

1 All parts of dwellings and accessory buildings and structures shall be designed, constructed and maintained to support safely their own weight and all other loads and forces to which they may be subjected.

2 Assumed minimum live loads (uniformly distributed) for design purposes.

- a Ceiling or attic floor joists, no storage, none.
Attic floors, limited storage only, 20 lbs. per sq. ft.
Living room floors, 40 lbs. per sq. ft.
All other floors, 30 lbs. per sq. ft.

b Girders: Dead loads of floor, partition and ceiling constructions plus 50% of assumed live loads of floors plus combined dead and live loads of roof.

c Roofs, either pitched or flat: 20 lbs. per sq. ft. normal to the roof surface.

3 Wind loads

a On vertical faces: 20 lbs. per sq. ft. horizontally, any direction.

b Roofs or parts with slopes greater than 30 degrees: 20 lbs. per sq. ft. acting inward normal to surface, on windward slope only.

c Lifting force: 20 lbs. per sq. ft. To prevent sliding or overturning, anchor roofs to walls and columns, and walls and columns to foundations.

C Special Conditions and Tests.

When special conditions exist or arise during construction, which necessitate additional precautions, the Building Official may require work in excess of these requirements. Building Official may require tests in accordance with Appendix A at expense of owner.

D Vapor Barriers

- 1 Top floor ceiling. Install independent vapor barrier or one integral with insulating material immediately above ceiling interior finish.
- 2 Exterior wall. When coefficient of heat transmission is not more than 0.20 B.t.u. per hour per square foot per degree temperature difference and when material of high vapor resistance is used on outside, install vapor barrier immediately back of interior wall finish or one integral with insulating material on the warm side (inside) thereof.
- 3 Barrier permeability to be not more than 2.5 grains per hour per square foot per pound per square inch vapor pressure difference. Any sheet with fairly continuous coating of water-resistant material, such continuity being indicated by a glossy surface, is likely to meet this requirement.
- 4 Vapor barrier to be applied tightly against any electrical outlets, registers, or framed opening.

E Sound Transmission

Provide reduction in sound transmission in walls and floors separating apartments or living units at least equal to that of the following construction:

- 1 Walls. An 8 inch masonry wall furred and plastered on both sides.
- 2 Floors. Ordinary wood joist floor having finished flooring laid on 2 inch sleepers over 1 inch blanket insulation.

301 EXCAVATION**A Foundations, Trench Walls and Piers.**

- 1 Extend to solid ground. Do not place footing on filled ground.
- 2 Bottom of footings: Not less than 3'-6" below finished grade, except where placed on solid rock.
- 3 Protect against freezing. No concrete shall be placed on frozen ground.

B Basementless Spaces

- 1 Ground level at least 18 inches below bottom of floor joists and girders. Ground under dwelling to be approximately level.
- 2 Where ground level is below outside finish grade and poor drainage exists, the Building Official may require drainage.
- 3 Remove all debris, sod, tree stumps and other organic matter within area occupied by dwelling.

302 GRADING**A Backfill**

- 1 Place backfill adjacent to foundation walls in not more than 12 inch layers well tamped.
- 2 Do not use debris for backfilling. See 304-D-5.

B Grading

- 1 Grade to levels shown on drawings; smooth lawn area to an even grade.
- 2 Slope to drain surface water away from building.
- 3 In locations where natural surface drainage is not possible, such as in depressed driveways, install drains connected to sewer or dry well.
- 4 Slope of driveways, not to exceed 1 foot in 8 feet.

303 MASONRY MATERIALS

Masonry materials described below apply to all masonry and concrete work.

A Cement

- 1 Portland Cement. See Appendix A.
- 2 Prepared masonry cement for mortar. See Appendix A.

B Aggregate

- 1 Sand: Clean, hard and sharp, free from harmful materials, graded according to intended use.
- 2 Coarse aggregate:
 - a Crushed stone or gravel: Hard, strong crystalline rock, properly graded, clean and free from shale or other soft material.
 - b Light weight aggregate. See Appendix A.

C Water

Clean and free from harmful material.

D Lime

- 1 Hydrated lime. See Appendix A.
- 2 Quick lime, slake thoroughly. See Appendix A.

E Brick

- 1 Face Brick: Hardburned, quality at least equal to grade B.
- 2 Common brick. See Appendix A.
 - a Selected hard-burned common brick may be used for facing of exterior and interior walls.
 - b Salmon or soft brick may be used in interior walls when not exposed, and for back-up work.
- 3 Fire brick. See Appendix A
- 4 Concrete brick. See Appendix A

F Structural Hollow Clay Tile

- 1 Sound, kiln-burned units, free from defects.
- 2 Load-bearing tile. See Appendix A
- 3 Non-load bearing tile. See Appendix A

G Concrete Masonry Unit. See Appendix A

Sound and thoroughly cured.

H Stone

- 1 Rubble and cut stone: Good quality building stone.
- 2 Cast stone. See Appendix A

I Flue Lining

Glazed fire clay and vitrified tile, free from cracks or other defects.

J Glass Block. See Appendix A

304 CONCRETE WORK

A General

- 1 Materials. See 303
- 2 Water content not to exceed 7-1/2 gallons of water per bag of cement, including moisture in the aggregate.
- 3 Retempering of concrete not permitted.

B Plain Concrete**1 Minimum mix:**

- a 1 part portland cement, 2-1/2 parts sand, 4 parts coarse aggregate;
or
- b 1 part portland cement, 5 parts pit run aggregate; or
- c Controlled mix having minimum compressive strength at 28 days of
2,000 pounds per square inch.

C Reinforced Concrete**1 Design. See Appendix A****2 Minimum mix:**

- a 1 part portland cement, 2-1/2 parts sand, 4 parts coarse aggregate;
or
 - b Controlled mix having minimum compressive strength at 28 days of
2,000 pounds per square inch.
- 3 Reinforcing:** New billet steel bars, rail steel bars, welded wire fabric or cold drawn wire. See Appendix A

D Forms

- 1 Double forms required for all basement concrete foundation walls.
- 2 Side forms required for footings where soil conditions prevent sharp-cut trenches.
- 3 Build tight, straight, plumb, and brace rigidly.
- 4 Do not remove until concrete has thoroughly set.
- 5 Remove all forms, spreaders and stakes before backfilling.

E Placing

- 1 Place continuously unless otherwise allowed by Building Official.
- 2 When not placed continuously, clean score and wet the top surface of the concrete before continuing. Key all vertical joints.
- 3 Spade and rod concrete thoroughly in form work. Place in horizontal layers not more than 12 inches thick.

F Protection

- 1 In hot weather, protect concrete to prevent too rapid drying.
- 2 In freezing weather, maintain the temperature of the concrete above freezing until thoroughly set.

G Loading

Allow sufficient time for strength of concrete to develop before subjecting to loads or traffic.

H Footings**1 General:**

- a Design for proper distribution of superimposed loads.
- b Material: cast-in-place concrete.
- c Bear on solid, unfilled ground.
- d Reinforce with steel bars where footings cross or bear on filled trenches or other unstable soil.
- e Footing dimensions listed below are based upon soils of average bearing capacity (4,000 pounds per square foot). For soils of lesser bearing capacity or where unusual loading conditions exist, larger footings will be required.

- 2 Wall Footings:
 - a Minimum dimensions for spread footings shall be 10 inches deep by 20 inches wide, except that masonry veneer on frame and solid masonry walls shall be 12 inches deep by 24 inches wide.
 - 3 Pier, Post and Column Footings:
 - a One-story dwellings: minimum area, 4 square feet; thickness, 1-1/2 X the projection, minimum, 12 inches.
 - b Dwellings over one-story: minimum area, 6 square feet; thickness, 1-1/2 the projection, minimum 12 inches.
 - 4 Chimney Footings:
 - a One-story dwellings: minimum thickness, 12 inches; minimum projection each side, 4 inches.
 - b Dwellings over one-story: minimum thickness, 12 inches; minimum projection each side, 6 inches.
 - c Pour integral with wall footing when chimney occurs in outside wall or inside bearing wall.
- I Footing Drain Tile. See Appendix A.
- 1 Required on outside of basement footings. Minimum diameter, 4 inches.
 - 2 Cover tile with 12 inches gravel or crushed stone.
 - 3 Connect with tight-joint glazed tile to sewer, dry well, or other outlet.
- J Concrete Foundation Walls Cast in Place. (For masonry unit foundation walls, see 305-B)
- 1 General
 - a Materials. See 303.
 - b Walls supporting frame construction: Extend concrete not less than 6 inches above adjoining outside finished grade.
 - c Walls supporting masonry veneered wood frame: Extend foundation so that wood portion of wall is not less than 6 inches above outside finished grade.
 - 2 Minimum thickness:
 - a Not less than that of wall supported.
 - b Supporting porch slabs, steps and one-story accessory wood frame structures without basement, minimum 6 inches.
 - c Interior walls not subject to lateral pressure, 8 inches minimum.
 - d All other walls, 10 inches minimum
 - 3 Girder pockets. Provide 4 inch end bearing on main wall for girder. Form pocket for wood girder 1 inch wider than girder.
 - 4 Sill anchor bolts to be installed:
 - a Diameter, 1/2 inch minimum.
 - b Minimum length, 10 inches.
 - c Provide washer under nuts on bolts.
 - d Spacing, not more than 8 feet on center; minimum, 2 bolts in each piece.
 - 5 Anchorage for intersecting walls and slabs. Provide dowell bar anchorage for porch and terrace slabs, concrete or masonry steps and area walls, which adjoin foundation walls. For basementless portions and attached garages, embed four 1/2 inch round hooked bars 4 feet long in main wall, two near top and two near bottom of attached wall.
 - 6 Chimney foundations: Start at level of lowest adjacent foundation wall footings.
 - 7 If special or unforeseen soil conditions warrant, the Building Official may require either reinforcement of wall or increased thickness.
 - 8 Dampproofing and water proofing. See 305-C.

K Concrete Floor Slabs on Ground.**1 Construction:**

- a Fill under slabs: Gravel, sand, screenings, or crushed rock, minimum thickness 4 inches. Earth underfill thoroughly leveled and free from vegetable matter, thoroughly tamped.
- b Wire mesh reinforcing: When required, minimum weight 40 pounds per 100 square feet.
- c Bottom of slab: Not lower than top of footing. Provide at least 4 inch bearing on footing.

2 Cement floor finish:

- a Finish basement slab with steel trowel.
- b Integral finish on concrete slab.

3 Slabs on ground used as a base for floors or as a finish floor in habitable rooms.

- a Minimum thickness, 4 inches.
- b Provide membrane water proofing directly under slab, at least 30 pound felt, lapped 4 inches.

4 Basement floor slabs: Minimum thickness, 4 inches.**5 Garage Floor slabs: Minimum thickness, 4 inches.****6 Terrace and porch floor slabs:**

- a Minimum thickness, 4 inches.
- b If reinforced, fill may be omitted.
- c Install metal flashing between slabs and all wood construction.
See 311-F

7 Slabs on ground used to support interior bearing walls or partitions: Thicken to at least 10 inches for a width of 20 inches.**L Exterior Wood Stairs**

Wood construction shall be at least 2 inches above walk or finished grade.

M Reinforced Concrete Floor on Precast Joist.

- 1 Minimum bearing of joists, 3 inches.
- 2 When span exceeds 15 feet, shore at mid span until slab is set.
- 3 Structural design based on T-beam action not acceptable when metal lath or paper backed mesh is used for slab forms.

305 MASONRY WORK**A General**

- 1 Materials. See 303.
- 2 Mortar:
 - a Masonry below grade, portland cement mortar; 1 part portland cement, 3 parts sand by volume. Lime, not more than 25 percent of the cement by volume, may be added.
 - b All other masonry:
 - 1 Portland cement mortar. See (2a) above.
 - 2 Cement-lime mortar: 1 part portland cement, 1 part lime putty, 6 parts sand by volume.
 - 3 Prepared masonry cement mortars; 1 part masonry cement, 3 parts sand by volume; add no materials other than sand and water.
 - c Retempering of mortar not permitted.

- 3 Joints.
 - a Maximum thickness 1/2 inch. All joints to be uniform in thickness.
 - b Solid masonry units: Fill joints solid.
 - c Hollow masonry units: No through mortar joints.
 - d Point all joints solid both sides of wall. Weather or tool outside and exposed inside joints unless otherwise acceptable to the Building Official.
 - 4 Bonding:
 - a Brick masonry: Header course consisting of alternate through header and stretcher every seventh course, or one through header in every 240 square inches, uniformly placed throughout wall.
 - b Rubble stone masonry: Bond stones at least 4 inches thicker than other stones; minimum 20 percent of wall area. Stagger verticle joints.
 - c Intersecting concrete and masonry walls; Bond together.
 - 5 Closed cell hollow units: Use for rough openings, corners, and wall intersection. Filling exposed ends of cells not permitted.
 - 6 Protection. Provide frost protection acceptable to Building Official when temperature falls below freezing, except that no masonry work shall be done in temperatures below 20°F.
 - 7 Loading. Allow sufficient time for strength of masonry to develop before subjecting to loads.
- B Masonry Unit Foundation Walls. (For cast-in-place concrete foundation walls, see 304-J)
- 1 General
 - a Materials. See 303.
 - b Walls supporting wood frame construction: extend not less than 6 inches above adjoining outside finish grade.
 - c Walls supporting masonry veneered wood frame: Extend foundation so that wood portion of wall is not less than 6 inches above outside finish grade.
 - d Walls of hollow masonry units: Cap with minimum of 4 inches of solid masonry or concrete. Hollow units filled with concrete not acceptable.
 - e Concentrated loads under ends of girders bearing on hollow masonry unit foundation walls: Support on minimum of 4 inches solid masonry or concrete.
 - 2 Minimum thickness:
 - a Not less than that of wall supported.
 - b Masonry unit walls, minimum thickness 12 inches.
 - c Flat-bed, square-edge stone: 12 inches.
 - d Rubble stone: 16 inches.
 - 3 Girder pockets: Provide 4-inch end bearing for girder. For wood girder, leave 1/2 inch space each side.
 - 4 Sill anchor bolts to be installed.
 - a Diameter: 1/2 inch minimum.
 - b Minimum length in masonry unit walls: 15 inches.
 - c Provide washer under nuts on bolts.
 - d Spacing: not more than 8 feet on center, minimum 2 bolts in each piece.
 - 5 Anchorage for intersecting walls and slabs: Provide anchorage for porch and terrace slabs, concrete or masonry steps and areawalls, which adjoin foundation walls.
 - 6 Chimney foundations: Start at a level of lowest adjacent foundation wall footings.

- 7 If special or unforeseen soil conditions warrant, the Building Official may require either reinforcement of wall or increased thickness.

C Dampproofing and Waterproofing.

- 1 Dampproof basement or cellar walls on exterior from finish grade to outside edge of footing:
 - a Masonry unit walls: Apply 1/2 inch thick portland cement plaster coat forming a cove at the footing, over which apply at least one heavy coat of undiluted hot tar, asphalt or compound acceptable to the Building Official.
 - b Concrete walls cast in place: Apply at least one heavy coat of undiluted hot tar, asphalt or compound acceptable to the Building Official.

D Piers.

- 1 Piers supporting exterior walls. Acceptable for only one-story accessory buildings and open porches.
- 2 Materials: Masonry units or cast-in-place concrete. See 303.
- 3 Minimum sizes in inches:
 - a Masonry: 12" x 12".
 - b Plain concrete: 10" x 10" or 12 inch round.
- 4 Maximum spacing:
 - a Exterior wall piers supporting floor joists: 8 feet on center.
 - b Exterior wall piers in line parallel to joists and interior piers: 12 feet on center.
- 5 Minimum height above grade, 6 inches.
- 6 When of hollow masonry units, cap with at least 4 inches solid masonry or concrete. See 305-B-1-e.
- 7 Sill anchor bolts or dowels to be installed.

E Exterior Masonry Walls Above Grade.

- 1 Materials: Masonry or cast-in-place concrete. See 303
- 2 Minimum thickness, 8 inches.
- 3 Maximum height for 8 inch thickness: 22 feet from grade to eaves; or 30 feet from grade to ridge in gable ends. For greater heights, minimum thickness 12 inches except top 22 feet.
- 4 Backing, when used, solid or hollow masonry units, minimum thickness:
 - a Bonded to facing, 4 inches.
 - b Tied to facing with sheet metal ties, 8 inches.
- 5 Furring when interior finish is applied: Not less than 1 inch wood strips. Spacing as permitted for interior finish. See 313. Bituminous waterproofing materials on masonry not acceptable for plaster base. Install horizontal furrier strips at ceiling and floor to form fire stops and prevent convection.
- 6 Lintels. Size to be determined by span in each case. No concentrated loads over nonreinforced lintels.
 - a Lintels may be:
 - 1 Precast concrete and brick reinforced.
 - 2 Stone.
 - 3 Masonry arch.
 - 4 Steel. (See Appendix A)

- b Support on 4 inches of solid masonry.
 - 7 Rafter plate anchor bolts to be installed:
 - a Diameter, 1/2 inch minimum.
 - b Minimum length in masonry unit walls, 15 inches; poured concrete walls, 10 inches.
 - c In masonry walls, washer and 3 inch square plate on bolts.
 - d Spacing, not more than 8 feet on center.
 - 8 Radiator recesses:
 - a Construct at time wall is built.
 - b Maximum recess depth, 4 inches in 8 inch walls, 8 inches in 12 inch walls.
 - c Back and sides of recess to be waterproofed and insulated.
 - d Width under windows not greater than rough opening.
 - 9 Vertical chases;
 - a Construct at time wall is built.
 - b Maximum length for chases where net wall thickness is 8 inches or less, 4 feet.
 - c Maximum chase depth, 4 inches.
 - d Back and sides of chase to be plastered with one-half inch of Portland cement mortar.
 - 10 Horizontal chases:
 - a Not acceptable unless wall thickness is at least 4 inches greater than thickness required under 305-E-2.
 - b Maximum depth, 4 inches.
- F Masonry Veneer.
- 1 Minimum thickness:
 - a Brick, 3-3/4 inches.
 - b Ashlar stone masonry, 4 inches.
 - c Rubble-stone masonry, uncoursed (field stone), 12 inches; mosaic or random, 12 inches; coursed, one story, 8 inches; over one story, 12 inches.
 - 2 Masonry veneered wood frame construction. Veneer applied over sheathing with air space between.
 - a Air space: 3/4 inch between masonry veneer and sheathing.
 - b Base flashing: Saturated asphalt felt not less than 15 pounds per square or copper extending over top of foundation wall from outside face of wall and not less than 12 inches up on sheathing. Base flashing may be omitted if foundation is offset at least 2 inches.
 - c Apply water resistant building paper or saturated asphalt felt over sheathing. Lap base flashing at least 4 inches.
 - d Bonding: Corrosion-resisting metal ties spaced not more than 15 inches vertically and 32 inches on center horizontally: When other than wood board sheathing is used, secure ties through to studs with corrosion-resisting nails of length sufficient to penetrate wood at least 1 inch.
 - e Lintels. Size to be determined by materials and span in each case. Bearing, at least 4 inches. Arches permitted.

G Cavity Walls.

- 1 Minimum thickness: facing (outer leaf) 3-3/4 inches; backing (inner leaf) 3-3/4 inches; total with cavity, 10 inches.
- 2 Maximum height above grade for minimum thickness; 22 feet to eaves; 30 feet to ridge at gable ends.
- 3 Lay units with full flat bed and vertical joints.
- 4 Tie each 3 square foot of facing to backing with approved rigid, non-corrodible tie bar, at least 1/4 inch in diameter. Embed ties in horizontal joints. Also locate ties not more than 3 feet apart within 12 inches of perimeter of all openings. Z bars shall have 6 inch shank length and 3 inch legs bent to 90 degree angles. Ties used with hollow units with cells vertical shall be rectangular in shape.
- 5 Flash with a non-corrodible metal sheet over tops of all openings, at window sills and at bottom of cavity wall.
- 6 Provide weep holes along flashing. Keep cavity clear of mortar droppings.

H Interior Masonry Walls.

- 1 Material: Masonry or cast-in-place concrete.
- 2 Pipe recesses: Construct at time walls are built.
- 3 Party and fire walls:
 - a Minimum thickness: Cast-in-place concrete, 6 inches; masonry units 8 inches. Chases or recesses not permitted. See d below.
 - b Flat roofs: Extend above roof, flash and cap with stone, concrete, vitrified tile, or terra cotta.
 - c Under pitched roofs: Build masonry solid to underside of roof sheathing unless carried above roof.
 - d Sound transmission, see 300-E.
- 4 Bearing partitions:
 - a Minimum thickness: Plain concrete, 6 inches; masonry units, 8 inches.
 - b Sections of walls with distance between openings 2 feet or less: Solid masonry units or hollow units filled with concrete.
 - c Lintels: Steel, reinforced concrete or masonry arches. Minimum, 4 inch bearing upon solid masonry at least 4 inches thick.
 - d Joist bearings: Solid masonry at least 4 inches thick.
 - e Girder bearing: Solid masonry at least 8 inches thick.
- 5 Nonbearing partitions:
 - a Minimum thickness, 3 inches.
 - b Lintels: Steel, reinforced concrete or masonry, or masonry arches.

I Chimneys.

- 1 Provide masonry chimney.
 - a Separate flue required for each fire place.
 - b Separate flue required for each appliance fired with natural-draft oil burner. Separate flues required for all other equipment, depending upon sustained chimney draft for proper operation, unless combined flue is specifically approved by the Building Official.
- 2 Materials: solid masonry; footing concrete cast in place.

- 3 Effective flue area: At least as recommended by the manufacturer of equipment connected to chimney and at least equal to area of outlet (smoke or vent) of equipment connected to it, minimum diameter for house heating flue, 8 inches. For fireplaces, effective area not less than 1/10 of fireplace opening.
- 4 Chimney linings, withes and walls:
 - a Glazed fire clay flue lining required in all chimneys for liquid and solid fuels. When gas is used as fuel, provide flue lining of metal or composition acceptable to the Building Official, or glazed fire-clay lining or vitrified tile lining, bell and spigot type, bell end up, all with joints made with acid-resisting mortar. Provide drain to dispose of condensation.
 - b Two flues may be grouped without withes provided joints of linings are staggered.
 - c Withes separating flues or groups of flues with linings not staggered, 3-3/4 inches minimum thickness.
 - d Walls, minimum thickness, 3-3/4 inches in addition to lining.
- 5 Height of chimney: As recommended by equipment manufacturer, and not less than 2 feet above the ridge of the roof that the chimney penetrates and not less than 2 feet above the highest ridge within 15 feet of the chimney.
- 6 Cap chimney to form wash from flue to outside edge, minimum thickness, 2 inches.
- 7 Metal thimbles and clean-out doors to be built in at the time chimney is constructed.

J Fireplaces.

- 1 Smoke chamber and damper required in all fireplaces.
- 2 Minimum wall thickness: 8 inches in addition to the lining.
- 3 Ash dump: When provided, empty into concrete or masonry chamber provided with metal cleanout door.
- 4 Lining: 2 inch fire brick or other material acceptable to Building Official.
- 5 Hearth:
 - a Support independently on masonry or concrete.
 - b Projection from chimney breast, at least 16 inches.
 - c Width: At least 8 inches wider than fireplace opening on each side.
 - d Material, incombustible.
 - e Combined thickness of hearth and support, 6 inches.
- 6 Fireplace opening lintel: use brick arch, concrete, stone or steel.
- 7 Facing: masonry, no combustible material closer than 3-1/2 inches to fireplace opening.

K Glass Block.

- 1 May not use as load-bearing units.
- 2 Maximum size of unsubdivided panel: area 144 square feet; length 25 feet; height 20 feet.
- 3 Provide for expansion.

306 STRUCTURAL STEEL AND IRON

A General.

- 1 Structural Steel. See Appendix A
- 2 Design, fabrication, and erection. See Appendix A.

B Beams and Girders.

- 1 Connections:
 - a Design to carry superimposed loads.
 - b Rivet, bolt, or weld.
- 2 Bearing: On walls, minimum, 4 inches.
- 3 Bearing Plates:
 - a Design to distribute load, minimum thickness, 5/16 inch.
 - b Bed in portland cement mortar.
 - c Plates may be omitted under wideflange type steel beams if width of flange provides sufficient bearing area so that allowable compressive stress of supporting material is not exceeded.

C Columns.

- 1 Material:
 - a Standard shape, steel or cast iron.
 - b Concrete-filled steel pipe, new material, standard weight or heavier.
 - c Boiler tubing not acceptable.
- 2 Bases and caps: Steel or cast iron.
 - a Caps: Rivet or bolt to steel girders; Spike or lagscrew to wood girders.
 - b Bases: Anchor by bolts or embed in concrete.
- 3 Shims, metal. Loose shims not acceptable.

307 WOOD CONSTRUCTION

A Lumber.

- 1 Structural Stress-Graded Lumber. Spans for structural stress-graded and marked lumber shall be determined from National Lumber Manufacturers Association publications. See appendix A.
- 2 All lumber shall be well seasoned. Lumber 2 inches thick and less shall have moisture content not to exceed 19 percent at the time dwelling is enclosed. See 313.
- 3 Lumber dimensions:
 - a Nominal sizes are given in these requirements unless noted otherwise.
 - b Minimum finish dimensions, width and thickness, as follows:

(Dimensions in Inches)

Nominal	Actual	Nominal	Actual	Nominal	Actual
1	25/32	4	3 5/8	8	7 1/2
2	1 5/8	5	4 5/8	10	9 1/2
3	2 5/8	6	5 5/8	12	11 1/2

B Framing, General

- 1 Structural framing members:
 - a Splicing between bearing points not permitted.
 - b When structural strength is impaired by cutting, drilling, or by inherent defects, replace or reinforce members in manner acceptable to Building Official.
- 2 Framing at chimneys.
 - a Bearing of framing members on chimney masonry not acceptable. Piers built integral with chimney may be used for girder bearing provided end of girder is at least 2 inches away from chimney masonry.
 - b Framing members: Not closer than 2 inches to chimney masonry. Fill 2 inch space with fire-resistive insulating material. Space may be 1/2 inch if asbestos board 1/4 inch thick and same width as framing members is used between masonry and framing.
- 3 Firestopping:
 - a Firestop all furring, partitions and outside stud walls at level of each floor or ceiling, and at juncture of roof rafters and wall.
 - b Wood or masonry, tightly fitted, or other methods acceptable to Building Official, may be used.

C Floor Framing.

- 1 Columns and posts:
 - a Structural steel or iron. See 306.
 - b Wood posts: Bear on concrete base resting on footing, top of base 3 inches above finish floor; securely fasten top of post to girder. If necessary for bearing, install bearing plate or cap secured to both post and girder.
- 2 Girders:
 - a Material: Structural steel, reinforced concrete, solid wood, or built-up wood.
 - b Spans for wood girders: Determine in accordance with sound engineering practice and subject to approval of the Building Official.
 - c Joints of solid and built-up wood girders to be made over pier or column supports only.
 - d Air space each side of wood girders framing into masonry, 1/2 inch.
- 3 Sills:

Level and grout with portland cement mortar. Wood shingles, chips, or similar material are not acceptable for permanent shims.
- 4 Joists:
 - a Maximum spans for wood are as follows:

MAXIMUM ALLOWABLE SPANS FOR FLOOR JOISTS
Of Other Than Structural Stress-graded and Marked Lumber

Lumber Size		Spacing Center to Center Inches	Maximum Allowable Spans (Clear) For			
			Living room floors Fl. ceiling below. Assumed live load 40 lbs. per sq.ft.		Other floors and conditions. Assumed live load 30 lbs. per sq.ft.	
Nominal Inches	Actual Inches		Ft.	In.	Ft.	In.
2 x 6	1 5/8 x 5 5/8	24	6	9	7	7
		20	7	5	8	4
		16	8	4	9	3
		12	9	7	10	9
2 x 8	1 5/8 x 7 1/2	24	9	2	10	1
		20	10	0	11	1
		16	11	2	12	5
		12	12	11	14	3
2 x 10	1 5/8 x 9 1/2	24	11	6	12	10
		20	12	7	14	0
		16	14	2	15	8
		12	16	3	18	1
2 x 12	1 5/8 x 11 1/2	24	14	0	15	6
		20	15	4	16	11
		16	17	1	18	11
		12	19	9	21	11
3 x 8	2 5/8 x 7 1/2	24	11	7	12	10
		20	12	9	14	1
		16	14	2	15	4
		12	16	5	16	11
3 x 10	2 5/8 x 9 1/2	24	14	8	16	3
		20	16	0	17	10
		16	18	11	19	4
		12	20	9	21	4

- b Framing into headers or side of wood girders. Use steel joist hangers or wood bearing strip at least 2" x 3". Notch joists not more than 1/4 of joist depth.
- c Framing into side of steel girders. Allow 1/2 inch clearance over top of top flange. Secure to girder or to opposite joists, or bridge joist firmly at girder ends if other ends are fixed. Notch for bearing not more than 1/4 of joist depth.
- d Framing into masonry.
 - 1 Minimum bearing, 3 inches
 - 2 Fire cut or bevel, 2 inches.
 - 3 Second-story floor joists parallel with masonry: Tie to masonry with metal straps extending over and secured to at least 1 joist and not more than 8 feet on center.

- e Butt or lap joists over girders and bearing partitions.
 - 1 Butting: center and tie with metal straps or 1 inch thick wood ties at least 2 feet long.
 - 2 Lapping: at least 4 inches; spike together; maximum projection beyond bearing, 1 foot.
 - f Double joists:
 - 1 Under all bearing partitions and under plaster finished non-bearing partitions when parallel to floor joists.
 - 2 Where piping or duct work occurs block joists apart at 4 foot intervals.
 - 3 Under heading partitions, more than two joists may be required by the Building Official, depending upon loading conditions.
 - g Headers and trimmers:
 - 1 Headers 4 feet or less in length may be single; headers receiving three or more tail beams, support in steel hangers, or on ledger boards not less than 2" x 3". If header is over 7 feet in length, secure ledger to trimmer with lag screws.
 - 2 For openings at end of joist span with headers 4 feet or less, trimmers may be single.
 - 3 Use double framing under all other conditions.
 - h Cutting of floor joists:
 - 1 Notching top or bottom for piping and duct work is permitted to not more than 1/6 minimum required joist depth except no notching in middle third of span; otherwise install header.
 - 2 Holes may be bored through joists, maximum diameter 2 1/2 inches; edges not nearer than 2 inches to top and bottom of joists.
 - i Cross-bridging:
 - 1 Maximum spacing, 8 feet; minimum size, 1" x 3" double nail at each end; bridging split in nailing not acceptable.
 - 2 Rigid metal bridging may be used when acceptable to Building Official.
 - j Cantilevered construction: submit detail drawing.
- 5 Subflooring required.
- a Wood boards:
 - 1 Thickness, 1 inch; maximum width, 8 inches, unless triple-nailed.
 - 2 If end-matched (tongue and groove boards), no two adjoining boards to break joints over same joist space; each board to bear on at least two joists.
 - 3 Maximum joists spacing: 16 inches on center.
 - b Plywood:
 - 1 Minimum thickness, 5/8 inch, 5-ply.
 - 2 Maximum joist spacing: 16 inches on center.
 - c At chimneys: Lay 1/2 inch clear of masonry.
 - d Provide 1/2 inch clearance between subfloor and any masonry wall as partition parallel to the boards.

D Ceiling Framing. See 300-D

1 Joists:

- a Maximum spans for ceiling or attic floor joists are as follows:
 - 1 For no attic storage, maximum access opening is 600 sq. inches
 - 2 With larger access opening, design for limited attic storage
 - 3 With permanent or disappearing stair, design according to floor joist table in 307-C-4-a.

MAXIMUM ALLOWABLE SPANS FOR CEILING OR ATTIC FLOOR JOISTS
of other Than Structural Stress-graded and Marked Lumber

Lumber Size		Spacing Center to Center Inches	Maximum Allowable Spans (Clear) For			
			No attic storage. Assumed live load - none		Limited attic storage. Assumed Live load 20 lbs. per sq. ft.	
Nominal Inches	Actual Inches		Ft.	In.	Ft.	In.
2 x 4	1 5/8 x 3 5/8	24	8	9	6	0
		20	9	3	6	7
		16	10	0	7	4
		12	11	0	8	5
2 x 6	1 5/8 x 5 5/8	24	13	7	9	3
		20	14	4	10	2
		16	15	8	11	4
		12	17	1	13	1
2 x 8	1 5/8 x 7 1/2	24	18	1	12	5
		20	19	1	13	7
		16	20	11	15	2
		12	22	10	17	6
2 x 10	1 5/8 x 9 1/2	24			15	8
		20			17	2
		16			19	3
		12			22	1

- b Use ceiling joists as ties for rafters whenever possible.
 - c Bridging: Solid, 2 inches thick full depth of joists, staggered for end nailing. Joists 8 inches and over, 1" x 3" cross-bridging or rigid metal bridging may be used; maximum spacing, 8 feet on center.
 - d Framing of ceiling joists over girders and bearing partitions: As required for floor joists. See 307-C-4-e.
- 2 Hung ceilings, flat roof construction:
- a Minimum size 2" x 4" on edge separated by wood or metal hangers, not more than 10 feet on centers.
 - b Ceiling joist bridging not required.

E Roof Framing.

1 General

a Headers and trimmers:

- 1 Headers 4 feet or less in length may be single.
- 2 When chimney is at ridge or eaves and header is 4 feet or less, trimmers may be single; use double framing under all other conditions.
- 3 Dormer windows not supported on partitions: Double headers and rafters.

b Anchor wall plates for rafters and roof joists on masonry wall.
See 305-E-7

2 Pitched Roofs:

- a Minimum pitch. See 310-A-1
- b Maximum Rafter spans are as follows:

MAXIMUM ALLOWABLE SPANS OF RAFTERS AND FLAT ROOF JOISTS
Of Other Than Structural Stress-graded and Marked Lumber
Between Plate and Ridge or Intermediate Support For Wood or
Asphalt Shingles or Built-up Roofing

(Collar beams designed as compression members may be accepted as intermediate supports)

Lumber Size		Spacing C.to C. Inches	Maximum Allowable Spans (Clear) For Roof Slopes					
			Greater than 3 in 12 measured on slope		3 in 12 or less measured horizontally			
Nominal Inches	Actual Inches		Roofing Material weight 5 lbs. per Sq. ft. or less		Supporting finished ceiling		Not supporting finished ceiling	
			Ft.	In.	Ft.	In.	Ft.	In.
2 x 4	1 5/8 x 3 5/8	24	7	6				
		20	8	3				
		16	9	2				
		12	10	7				
2 x 6	1 5/8 x 5 5/8	24	11	8	8	7	10	2
		20	12	9	9	5	11	1
		16	14	3	10	6	12	6
		12	16	5	12	1	14	4
2 x 8	1 5/8 x 7 1/2	24	15	6	11	5	13	6
		20	17	0	12	6	14	10
		16	19	0	14	0	16	7
		12	22	0	16	2	19	2
2 x 10	1 5/8 x 9 1/2	24	19	8	14	6	17	1
		20	21	6	15	10	18	9
		16	24	1	17	9	21	0
		12	27	10	20	6	24	2

- c Rafters: Cut for level bearing and spike to wall plate; no portion of cut end of rafters to project beyond inside edge of wall plate; frame rafters opposite at ridge; provide tie for rafters to prevent thrust.
 - d Collar beams:
 - 1 Minimum size 1" x 6" or 2" x 4"; maximum spacing 4 feet on center.
 - 2 When ceiling joists do not serve as tie at plate line or are not below lower third of rafters, install ceiling joists (collar beams) same size as rafters on each pair of rafters, and make special provisions for tying the lower end of rafters to the floor or wall construction.
 - e Ridge boards: Not required for simple gable roofs where rafters frame opposite each other. All other types, use 2 inch member with depth not less than cut end of rafter.
 - f Valley rafters:
 - 1 Minimum thickness, 2 inches: minimum depth, not less than cut end of jack rafters.
 - 2 Maximum unsupported length of single valley rafters, 8 feet; double rafters, 12 feet.
 - 3 May be omitted when jack rafters of one roof frame on sole plate on top of roof sheathing of adjoining roof.
 - g Crickets or chimney saddles at upper side of all chimneys not in contact with ridge.
- 3 Flat Roofs:
- a Roof joist spans. See 307-E-2-b.
 - b Cross-bridging: Minimum size, 1" x 3" maximum spacing, 8 feet on center.
 - c Joists supporting hung ceilings. See 307-D-2.
 - d Framing of roof joists over girders and bearing partitions: As required for floor joists. See 307-C-4-e.
- F Exterior Wall and Bearing Partition Framing.
- 1 Studs:
- a Continuous lengths without splicing.
 - b Minimum size, 2" x 4".
 - c Maximum spacing for all construction, 16 inches on center; one-story detached accessory buildings, 24 inches.
 - d Maximum length for balloon frame, 20 feet; notch studs at second floor to receive 1" x 4" ribbon. Nail joists to studs.
- 2 Corner posts: Not less than three 2" x 4"s set to receive interior finish.
- 3 Corner Bracing:
- a Braces at external corners: 1" x 4", let into outside face of studs and plates, set approximately at 45 degrees, extend from sill to plate. Attaching ends of braces to blocks nailed to studs or plates not acceptable. May be omitted only when wood sheathing boards are laid diagonally.
 - b Openings near corner: Use 1" x 4" knee braces, extending from corner post to sill and to top plate. Extend over at not less than three stud spaces.
 - c Openings at corner: Brace as in (a), set as near opening as possible.

- 4 Sill Construction:
 - a Sill anchorage. See 304-J-4 and 305-B-4.
 - b Sills and girders on top of foundation walls and piers; level and grout with portland cement mortar; wood not to be used for permanent shims.
 - c Other methods may be used if detailed on drawings submitted with application and acceptable to Building Official.
 - 5 Window and door openings:
 - a Inner stud on jambs: Extend in one piece from header to bearing and nail to outer stud.
 - b Headers for usual loading conditions:

Size	Maximum span
Two 2x4s on edge	3'-6"
Two 2x6s on edge	4'-6"
Two 2x8s on edge	6'-0"
Two 2x10s on edge	7'-6"
 - c Where headers support concentrated loads or are subjected to other unusual loading conditions, the header shall be specially designed.
 - d If desired, truss construction may be used.
 - 6 Plates:
 - a Top plates, two 2x4s. Lap at corners and intersecting partitions. Single 2x4 acceptable for bearing partitions when studs occur directly under joists or rafters. When plates are cut for piping or duct work, install steel angles on each side of plate not less than 1 1/2" x 1 1/2" x 1/8", to serve as plate ties and bearing for joists. Spike angles to joists and plates, using not less than 3 nails at each end. Alternate method for reenforcing cut plates: solid full depth 2 inch header and metal tie 1/2 inch by 12 gauge with three heavy nails or screws at each end.
 - b Where headers support concentrated loads or are subjected to other unusual loading conditions, header shall be specially designed.
 - c Sole plates, minimum thickness, 2 inches; exterior wall studs may bear on the sill or on a sole plate on top of subfloor.
 - 7 End studs of bearing partitions connecting to masonry walls. Anchor with bolts or spikes.
 - 8 Wood bearing partitions in cellars or basements are not acceptable.
 - 9 Studs to be continuous (balloon frame) when exterior is to have continuous stucco finish.
- G Non bearing Partition Framing.
- 1 Studs:
 - a Use continuous lengths without splicing.
 - b Partitions exceeding 6 feet of unsupported length containing openings; Size and spacing same as bearing partitions.
 - c Partitions less than 6 feet unsupported length with openings:

Minimum Size	Maximum spacing
2x4s (2" thickness)	16" on center.
2x4s (4" thickness)	24" on center.
2x3s (3" thickness)	16" on center.
 - d Partitions 6 feet or over in length without openings:

Minimum size	Maximum spacing
2x4s (2" thickness)	16" on center.
2x3s (3" thickness)	24" on center.
2x4s (4" thickness)	24" on center.

- 2 Openings:
 - a In 2 inch thick partitions: Inner stud on jambs, size 2" x 2" extend in one piece from header to bearing and nail to outer stud; or single frame with 2" x 6" jambs continuous from top plate to sole plate with header notched 2 inches into each jamb.
 - b In 3 inch and 4 inch thick partitions: Single framing permitted provided opening does not exceed 3 feet in width and header is secured by spiking through jamb studs.
 - c Headers.

Opening width, 3 feet or less:

 - 2"-thick partition, 2" x 4" on edge.
 - 3"-thick partition, 2" x 3" flat.
 - 4"-thick partition, 2" x 4" flat.

Opening width, over 3 feet:

 - 2"-thick partition, 2" x 4" on edge.
 - 3"-thick partition, two 2x3s flat.
 - 4"-thick partition, two 2x4s.
- 3 Top and sole plates: Minimum thickness. 2 inches; lap top plate at outside walls and at bearing partitions.
- 4 Wardrobes, cabinets or casework acceptable as non-bearing partition.
- 5 Solid plaster partitions.
 - a Maximum unsupported length 16 feet.
 - b Core: 3/8 or 1/2 inch gypsum lath continuous from floor to ceiling and full width of door frames. Set in grooves of wood sill and plate members and of jambs and heads of door frames. Grooved member not required at intersection of walls to be plastered. At masonry wall intersections, tie or lace cornerite through lath core with wire. Butting units may be fastened as recommended by manufacturer and as approved by the Building Official.
 - c Sill and plate members: Finished thickness, 1-1/4 inches minimum. Securely nail to floor and structural framing.
 - d Doorframes: Mill built as finished frame. Thickness 1-5/8 inches minimum. Prime coat all sides. Secure to floor framing and sill members. Provide anchor for plaster by driving 8d nails on each side of lath, 3/8 inch out from groove, at 30 degree angle with plane of lath, on 12 inch centers staggered, then bend back against lath.
 - e Pipes and conduits: Plumbing pipes, not permitted. Moisture resistant electrical conduit, tie securely to face of lath. Use shallow outlet box.
 - f Coat core both sides with gypsum plaster to overall thickness of 2 inches, three coat or two coat double-up work.
- H Wall Sheathing. See 300-F. Sheathing may be omitted on detached accessory buildings not containing habitable rooms.
 - 1 Wood boards:
 - a May be used under any exterior finish material.
 - b Minimum thickness, 1-inch (25/32); maximum width, 8 inches unless triplenailed; maximum stud spacing 24 inches on center.
 - c Break joints over center of studs unless end-matched (T&G) boards are used; no two adjoining end-matched boards to break joints over same stud space and each board to bear on at least two studs.
 - d Application: When laid diagonally extend at 45 degrees in opposite directions from each corner; apply horizontally under stucco finish.

2 Plywood.

a May be used under any exterior finish material.

b	Minimum thickness	Maximum stud spacing
	5/16 inch	16 inches
	3/8 inch	24 inches

c Types of finish which affect the minimum thickness of plywood used:

1 Under wood shingles: If 5/16 inch plywood is used, apply shingles over 1" x 2" nailing strips using copper or galvanized nails for attaching shingles. Nailing strips may be omitted if barbed nails are used for attaching the shingles.

2 Under asbestos-cement shingles and siding, if 5/16 inch thick plywood is used apply siding or shingle material with barbed nails. Do not apply over wood nailing strips.

3 Fiber board: Structural, See Appendix A.

a Under wood shingle siding: Apply 1" x 2" nailing strips over sheathing, spaced according to shingle exposure.

b Asbestos-cement siding or asbestos-cement shingles shall be attached with special metal fastening devices.

c	Minimum thickness	Maximum stud spacing
	1/2 inch	16 inches
	3/4 inch	24 inches

4 Gypsum Board. See Appendix A

a Asbestos-cement siding or asbestos-cement shingles shall be attached with special metal fastening devices.

b Minimum thickness, 1/2 inch; maximum stud spacing, 16 inches.

c Under wood shingle siding: Apply 1" x 2" nailing strips over sheathing, spaced according to shingle exposure.

I Sheathing Paper

1 Material

a Water-resistant building paper.

b Asphalt saturated felt.

c Vapor resistance shall be less than that of vapor barrier provided on inside of wall.

2 Application

a Use over all types of sheathing except as noted in I-3.

b Apply shingle fashion, 4 inch lap. Lap 4 inches over paper strips around openings.

c Use 6 inch wide strips behind exterior trim of all exterior openings.

3 Paper not required over gypsum or fiber board, factory treated to be moisture resistant and each piece marked "Water-Repellant", (except when used behind masonry veneer and stucco) provided:

a Necessary corner and opening cuts are caulked with elastic waterproof caulking material. Corner joints may be protected with 18 inch widths of sheathing paper applied shingle fashion.

b At heads of openings, bottom edge of board is located to permit head flashing to be extended under and turned up behind sheathing, and joint between head flashing and board is caulked.

J Roof Sheathing.

1 Wood boards:

- a May be used under any roofing material.
- b Minimum thickness, 1 inch (25/32); maximum width 8 inches, maximum rafter spacing, 24 inches on center.
- c Break joints over center of rafters unless end-matched (tongue and groove) boards are used; no two adjoining end-matched boards to break joints over same rafter space and each board to bear on at least two rafters.
- d Application: Lay closed under all roof material except wood shingles. Under wood shingles, use 1" x 4" shingle lath spaced according to shingle exposure.

2 Plywood:

- a May be used under any roofing material.
- b Minimum thickness:

<u>Roofing material</u>	<u>Rafters Maximum Spacing (inches)</u>	<u>Plywood Minimum Thickness (inch)</u>
Wood and asphalt shingles	16 20 24	5/16 3/8 1/2
Slate, tile and asbestos-cement ^v shingles	16 24	1/2 5/8
Flat roofs	16	5/8

- c Under wood shingles; apply 1" x 2" nailing strips over plywood less than 1/2 inch thick, spaced according to shingle exposure.
 - d Protect exposed edges of sheathing along eaves and rake of roof with mouldings or sheet-metal flashing. Flashing along eaves may be integral with gutters. If gutters are not installed, form the flashing to provide a drip.
- 3 Fiber board is not acceptable for roof sheathing.

K Stair Stringers.

- 1 Provide solid bearing at top and bottom.
- 2 Effective depth of wooden stringers, minimum, 3 1/2 in.
- 3 Open basement stairs: Minimum stringer thickness, 2 in.
- 4 Third stringer: Install if treads are less than 1 1/8 inches thick and stair is more than 2'-6" wide.

L Caulking

- 1 Caulk around exterior openings in masonry or masonry veneer walls.
- 2 Caulk at intersections of wood and masonry except when flashed. This does not apply to tops of foundations.

309 EXTERIOR WALL FINISH. See 307-H

A Wood siding.

- 1 Use well-seasoned material. Moisture content not to exceed 15 percent.
- 2 Nail at each bearing with hot-dipped galvanized or cement-coated nails.
- 3 Bevel siding:
 - a Finish dimensions to comply with the following limitations as to minimum top and butt thickness:

Nominal width (in.)	Thickness at top (in.)	Thickness at butt (in.)
4 to 6	3/16	7/16
8	3/16	9/16
10 to 12	3/16	11/16
 - b Minimum headlap: 1 inch for 4 inch width; 1 1/4 inches for widths over 4 inches.
 - c Nail near butt only. Do not nail through board underneath.
- 4 Rustic and drop siding: Minimum thickness, 3/4 inch (finished); maximum width 8 inches (nominal).
- 5 Shiplap or matched siding:
 - a Minimum thickness, 25/32 inch (finished); maximum width, 12 inches (nominal).
 - b Triple-nail all boards over 8 inches in width;
 - c When boards are applied vertically, set edges in white lead.

B Wood Shingle Siding.

- 1 Shingle grades.
 - a Single course siding, No. 1 or No. 2.
 - b Double course siding, No. 1 for exposed shingles; under course may be No. 1 or No. 2.
- 2 Minimum size:

Length (inches)	Thickness
16	5 Butts in 2 inches
18	5 Butts in 2 1/4 inches
24	4 Butts in 2 inches
- 3 Maximum exposure:

Shingle length - in.	Single course exposure - in.	Double course exposure - in.
16	7 1/2	12
18	8 1/2	14
24	11	16
- 4 Nailing:
 - a Nails: Copper or hot-dipped galvanized.
 - b Butt nail double coursing; exposed nails may be smallheaded.

C Asbestos-Cement Siding and Shingles. See 307-H-3-b.

- 1 Material. See Appendix A
- 2 Apply clapboards and shingles in accordance with manufacturers recommendations.
- 3 Nails, noncorrodible.

D Plywood.

- 1 Material, sound.
- 2 Grade mark, for exterior use, on each sheet of plywood.
- 3 Plywood, 3/8 inch thick, may be used on sheathed walls. If sheathing other than wood is used, install solid blocking between studding as provided in (4) below.
- 4 Installation:
 - a Protect edges prior to erection with paint, mixed 100 lbs. white lead paste, 1 3/4 gallons raw linseed oil and 1 pint dryer, applied without thinning.
 - b Vertical joints: To occur over studs.
 - c Horizontal joints: Install solid blocking between studding for nailing.
 - d Butt joints of square-edge material, whether exposed or covered by battens, fill with mastic.
 - e Corner boards: Apply over plywood or butt plywood against boards at all corners.
 - f Nails: Cement-coated or hot-dipped galvanized, flat head. Minimum spacing; on edge, 6 inches; on center, at intermediate bearings, 12 inches on center.

E Stucco. See 307-F-9 and 307-H-1-d

- 1 Lath for stucco. See Appendix A. Wood lath not acceptable.
 - a Expanded metal lath, painted; with large openings. 1.8 lbs. per sq. yd.
 - b Nails: electrolytic zinc-coated furring nails.
 - c Metal lath, held at least 1/4 inch away from sheathing by furring nails. Furring strips and self-furring lath not permitted.
- 2 Stucco:
 - a Materials. See 303 and Appendix A
 - b Mixture: 1 part portland cement, 3 parts sand, and hydrated lime equal to 10 percent of cement by volume; or prepared portland cement stucco used in accordance with manufacturer's recommendations.
 - c Thickness: 3 coat work, 1 inch total; 2 coat work, 5/8 inch total.
 - d Application:
 - 1 3 coat work, over wood frame.
 - 2 2 coat work, over masonry surfaces.
 - 3 Finish coat may be trowel coat of prepared exterior portland cement stucco.
 - 4 Thoroughly cover and embed lath in stucco.
 - 5 Keep wet 2 days after application of each coat.
 - 6 Drying time before application of finished coat, 7 days.
 - 7 Stucco not to be applied when temperature is lower than 40 degrees F.

310 ROOF COVERINGS

A General.

- 1 Roof Slope:
 - a Shingle and tile roof (except porches, 5 in 12 minimum.
 - b Shingle and tile roof of a porch or attached garage, 3 in 12 minimum.
 - c Built-up roofs (gravel or slag surface), 3 in 12 maximum.
 - d Built-up roofs with mineral surface cap sheet, 3 in 12 maximum.
 - e When materials and method of application provide precautions in excess of these 4 minimum requirements to assure a weather-tight roof, above roof slopes may be reduced subject to acceptance by Building Official.
- 2 Double starting row, on all shingle applications.
- 3 Nails for attaching roof covering, copper or hot-dipped galvanized nails.

B Asphalt Shingles.

- 1 Fire Underwriters' Class C label on each bundle.
- 2 Approximate shipping weights per square:
 - a Square butt strip, 210 pounds.
 - b Hexagonal strip, 215 pounds.
 - c Individual shingles, 250 pounds.
- 3 Exposure as required for Fire Underwriters' Class C label.
- 4 Headlap as recommended by manufacturers; minimum, 2 inches.
- 5 Double thickness at all points. Cut-outs and vertical spacing 3/4 inch or less may be disregarded.
- 6 Underlay:
 - a Asphalt-saturated felt: Weight approximately 15 pounds per 100 sq. ft.;
 - b No underlay required on roof slopes of 7 in 12 inches or more when package containers are stamped by manufacturer showing approximate shipping weight of 210 pounds per square; or when triple thickness is obtained at all points.

C Wood Shingles.

- 1 Edge-grain, tapered shingles (No. 1 grade).
- 2 Minimum size:

Length (inches)	Thickness
16	5 Butts in 2 inches.
18	5 Butts in 2 1/4 inches.
24	4 Butts in 2 inches
- 3 Maximum exposure:

Slope of Roof		Exposure for shingle length - inches		
Rise	Run	16	18	24
3 to 7	12	4	4 1/2	6
7 to 18	12	5	5 1/2	7 1/2
- 4 Underlay not permitted.

D Asbestos Cement Shingles.

- 1 Quality: Dense, hard structure and thoroughly seasoned. See Appendix A.
- 2 Fire Underwriters' Class A or B label on each bundle.
- 3 Underlay: one layer asphalt-saturated felt, approximately 30 pounds per 100 square feet.

- 4 American Method:
- a Standard shingle: Minimum weight per square, 470 pounds.
 Length of Shingle - in. Maximum Exposure - in.
- | | |
|----|-------|
| 16 | 7 |
| 15 | 6 1/2 |
| 12 | 5 |
- b Strip shingle: Minimum weight per square, 250 pounds.
- 5 Dutch Method:
- a Minimum weight per square, 265 pounds.
 b Minimum headlap, 3 inches.
 c Minimum sidelap, 4 inches.
- 6 French or Hexagonal Method:
- a Minimum weight per square, 250 pounds.
 b Minimum overlap 2 edges, 3 inches.
- E Tile Roofing.
- 1 Quality: Hard-burned roofing tile.
 2 Underlay: One layer asphalt saturated felt approximately 30 pounds per 100 square feet.
 3 Shingle tile, American Method.
- | Length of shingle - in. | Maximum exposure - in. |
|-------------------------|------------------------|
| 16 | 7 |
| 15 | 6 1/2 |
| 14 | 6 |
| 12 | 5 |
- 4 Interlocking tile and curved tile: Lay in accordance with manufacturer's recommendations.
- F Slate shingles:
- 1 Quality: Free from knots or knurls and of reasonably smooth cleavage. See Appendix A.
 2 Underlay: Asphalt saturated felt approximately 30 pounds per 100 square feet.
 3 Laid American Method.
- a Minimum thickness, 3/16".
 b Length of shingle - in. Maximum exposure - in.
- | | |
|----|-------|
| 18 | 7 1/2 |
| 16 | 6 1/2 |
| 14 | 5 1/2 |
| 12 | 4 1/2 |
| 10 | 3 1/2 |
- G Built-up Roofs.
- 1 Asphalt or tar and gravel coverings, including flashings: Comply with requirements of Underwriters' Laboratories, Inc., Built-up roof coverings, minimum 3-ply.
 2 Apply according to manufacturer's directions.
 3 Each ply of felt: Minimum weight, 14 pounds per 100 square feet.
 4 Surface with:
- a Roofing gravel or crushed stone: Approximately 400 pounds per 100 square feet; or
 b Crushed slag: Approximately 300 pounds per 100 square feet.
 c Other material approved as to quality and weight by Building Official.

- 5 Top ply of felt and crushed stone or slag surfacing may be replaced with one layer of mineral surfaced cap sheet, minimum weight 85 pounds per square.

H Metal Roofs.

- 1 Materials. See Appendix A.
 - a Galvanized sheet metal; 26-gauge sheets, 1.25-ounce (total weight both sides) zinc coating per square foot.
 - b Copper: 16-ounce soft (roofing temper).
 - c Roofing tin: 40-pound coating.
 - d Lead: Sheet lead, 2 1/2 lbs. per sq. ft.
- 2 Nails:
 - a Hard copper or copper alloy, for copper roofs.
 - b Hot-dipped galvanized, for galvanized, sheet metal roofs.
- 3 Seams, flat or standing; flat seams, locked and soldered.
- 4 Provide for expansion.

I Other types of roof coverings.

Roof coverings such as metal shingles, canvas or roll roofing: may be used when the type and weight of material, and method of application are acceptable to the Building Official.

311 FLASHING.

A Material. See Appendix A.

- 1 Copper: 16-ounce soft (roofing temper).
- 2 Galvanized sheet metal: 26-gauge, 1.25-ounce (total weight both sides) zinc coating per square foot.
- 3 Lead: Hard lead, 2 pounds; soft lead, 4 pounds.
- 4 Tin: 40-pound coating, painted both sides.
- 5 Other materials as provided for in 311.
- 6 Copper and zinc flashings, gutters and downspouts not to be used in conjunction with each other.

B Openings not protected by overhang.

- 1 Heads of openings, wood frame walls:
 - a Sheet metal extended behind finish siding material and turned down over outside edge of head trim unless drip cap extends behind and above bottom of finished material; or
 - b Three-ounce copper-coated building paper may be used provided flashing is not exposed to weather more than 2 inches. Extend behind siding. Blind tack at outside edge of drip cap, 1 inch on center.
- 2 Heads and sills of openings, masonry-veneered wood frame walls.
 - a Material: Sheet metal or membrane waterproofing material acceptable to Building Official.
 - b Head flashing: Extend from front edge of lintel, up and over top of lintel and up on sheathing under building paper.
 - c Sill flashing: Extend under masonry sill, up on sheathing and under wood sill.
- 3 Heads and sills of openings, masonry walls.
 - a Material: Sheet metal or membrane water proofing material acceptable to Building Official.
 - b Head flashing: Extend from front edge of lintel, up and over top of lintel, through wall and turn up 1 inch on inside surface.

- c Sill flashing: Extend under and behind masonry sill.
- 4 Heads of openings, stuccoed wood frame walls:
 - a Material: sheet metal.
 - b Drip: Form drip on front edge of drip cap and extend flashing up behind building paper underneath stucco.

- C Intersections.
 - 1 Provide sheet metal flashing for all horizontal and vertical intersections of stucco with other materials.
 - 2 All flashing in connection with masonry walls shall have flashing or counter-flashing built into masonry not less than one inch.

- D Valleys.
 - 1 Rigid shingle roof covering:
 - a Flash with sheet metal.
 - b Flashing on:
 - 1 Roof slopes less than 7 in 12, width 18 inches.
 - 2 Roof slopes 7 in 12 or more, width 12 inches.
 - 2 Asphalt shingle roof covering:
 - a Flash with sheet metal; or
 - b Two thicknesses of mineral surfaced roll-roofing material cut from rolls weighing not less than 85 pounds per square. Bottom strip, 18 inches wide, top strip at least 12 inches wide.

- E Roof and Wall Intersections.
 - 1 Sloping roof: Sheet metal flashings.
 - 2 Flat roof: Sheet metal or same material as roof covering. When sheet metal is not used, install 45 degree cant strip at roof and wall intersection.

- F Terrace or porch slabs. Suspended (reinforced) type or bearing on the ground, which abut wood construction at exterior wall.
 - 1 Flashing material: Sheet metal.
 - 2 Extend flashing at finish floors of terrace or porch from 1/4 inch outside exterior face of finish, turn up 4 inches behind exterior finish, thence turn down and through wall under wood construction to 1/2 inch beyond inside face of foundation. The horizontal projection of the flashing under the exterior finish is to be turned down the sides of the terrace or porch slab to the level where the flashing goes through the wall.

- G Chimneys.
 - 1 All chimney and roof intersections, sheet metal flashing.
 - 2 Cricket or saddle covering: Sheet metal.

312 GUTTERS AND DOWNSPOUTS

When dwelling is provided with a basement install gutters and downspouts unless omission is specifically permitted by Building Official.

- A Materials. See Appendix A.
 - 1 Copper, 16-ounce, hard (cornice temper).
 - 2 Galvanized sheet metal: 26-gauge sheets, 1.25 ounce (total weight both sides) zinc coating per square foot.
 - 3 Solid wood gutters: Paint inside with two coats pitch or three coats lead and oil after installation.
- B Basket strainers.
 - 1 Material: Copper wire for copper gutters, heavily galvanized wire for all other gutters.
 - 2 Install strainers in all gutter outlets to down-spouts.
- C Roof water disposal: Provide outlet acceptable to Building Official.

313 INTERIOR WALL AND CEILING FINISH

None shall be applied when moisture content of framing lumber remains over 19%.

- A Lath and Plaster. See Appendix A.
 - 1 Wood Lath:
 - a Maximum stud spacing, 16 inches on center.
 - b Lath, No. 1, 5/16 inch thick.
 - c Space lath 1/4 to 3/8 inch apart. Break joints every seventh lath, nail at each bearing.
 - 2 Expanded metal lath:
 - a Painted or galvanized lath.
 - b Minimum weights; maximum spacing of supports.

<u>Use</u>	<u>Pounds per yd.</u>	<u>Stud spacing - in.</u>
Walls:		
All dwellings	2.5	16
1 Story dwellings	x 3.4	20
	x 4.0	24
	xx 3.0	24
		<u>Joist Spacing - in.</u>
Ceilings	x 2.75	16
	3.4	16
	xx 3.4	24
x Flat rib		
xx High rib		

- 3 Insulating fiber boardlath:
 - a Minimum thickness, 1/2 inch.
 - b Lath size, 18" x 48". Lath, 24" x 48" may be used provided all joints at right angles to the framing members are covered with continuous strips of metal lath and ends of lath are nailed to solid bearing (framing members) at approximately 4 inches on center including intermediate supports.

- c Maximum stud or joist spacing, 16 inches on center.
- d Apply in accordance with manufacturer's directions.
- 4 Gypsum lath:
 - a Minimum Thickness, 3/8 inch.
 - b Size 16" x 48".
 - c Maximum stud or joist spacing, 16 inches on center.
 - d Apply in accordance with manufacturer's directions.
- 5 Lathing:
 - a Heads of openings: Install lath so vertical joints of first course of lath above head will not occur on jamb studs.
 - b Corner beads: Galvanized metal, for all external corners.
 - c Corner and joint reinforcing: Metal lath 2 1/2 inch lap on each surface.
 - d Over solid wood surfaces: install metal lath on strips or use furring nails. Lap metal lath on adjoining lath surfaces.
- 6 Plaster:
 - a Mix all plaster (lime and prepared) according to manufacturer's recommendations.
 - b Quick lime, slake thoroughly.
 - c Minimum thickness, 1/2 inch over lath base.
Finish all ceilings level and walls and corners, plumb and straight.
- 7 Drying Period: Allow sufficient time for plaster to dry thoroughly before application of trim.

B Ceramic Tile

- 1 Materials. See Appendix A.
- 2 Grade: To be at least Standard Grade.
- 3 Installation:
 - a Stud covering: 15-pound asphalt saturated felt applied shingle style (unless metal lath is paper-backed).
 - b Metal lath. See 313-A-2, for types and weights.
 - c Scratch coat: Portland cement plaster, minimum 5/8 inch thick, integrally waterproofed. Scratch thoroughly. Allow to dry before installing tile.

C Shower Walls.

- 1 Materials: Dense and water repellent. Plaster not acceptable.
- 2 Installation:
 - a Install in accordance with manufacturer's instructions.
 - b Minimum height: not below shower head.
 - c Caulk and protect joints at corners, bathtub, top edges of wainscot and at intersections of wainscot and other materials. Use moldings designed for the purpose or other materials satisfactory to the Building Official.

D Dry Wall Finish.

1	Minimum thickness:	Actual Inches		
	<u>Type of wall finish</u>	<u>Stud spacing</u>		
		<u>16</u>	<u>20</u>	<u>24</u>
	Wood boards	3/8	1/2	1/2
	Plywood	1/4	3/8	3/8
	Gypsum board	3/8	1/2	1/2
	Fiber board	1/2	3/4	3/4

- 2 For stud spacings exceeding 16 inches on center: Install 2-inch solid blocking behind all joints at right angles to framing members.
 - 3 Other types of boards, including compressed dense composition board less than 1/2 inch thick, may be used when acceptable to the Building Official. Maximum stud spacing 16" on center.
- E Heater Room Interior Finish.
- 1 Materials. 1-hour fire-resistive construction. See Appendix A.
 - 2 Installation.
 - a Apply over all combustible materials, including ceiling area, within 4 feet of heating unit and flue pipe.

314 FINISH FLOORS

- A Cement Floors.
- 1 Mix. See 304-B and 304-K-2.
 - 2 Heater room floors on wood construction where solid or liquid fuel is used:
 - a Minimum thickness, 4 inches.
 - b Use sheet metal over tops of joists for concrete forms or cut in 1-inch boards flush with top of joists. If wood boards are used, remove after the slab has set.
 - c Reinforce slab with wire mesh weighing not less than 30 pounds per 100 square feet, or with 1/4 inch bars spaced 1 foot on center each way.
 - 3 Heater room floors on wood construction where gas burning equipment raises temperature of floor to above 160 degrees, comply with the provisions of 2 above. See American Gas Assoc. specifications.
- B Wood Floors. See 307-C-5
- 1 Materials.
 - a Flooring: Kiln-dried material.
 - b Strip flooring, hardwood or softwood, minimum thickness 25/32 inch, maximum width 2 1/4 inches for hardwood, 3 1/4 inches for softwood. 3/8 inch thickness may be used where laid directly on a subfloor. Wider widths (plank flooring) and parquet flooring may be used when precautions are taken to prevent warping or cupping.
 - c Nails: Maximum spacing, 16 inches on center.
 - d Building paper or deadening felt: Apply under all finish flooring unless floor is insulated.
 - 2 Installation.
 - a Finish flooring over subflooring: Apply at right angles to subflooring except when subflooring is laid diagonally.
 - b Finish flooring on strips; Wood strips, minimum size, 1" x 2"; maximum spacing, 16 inches on center. Apply strips over building paper or deadening felt on top of subflooring.
 - c Strip flooring on concrete: Apply on not less than 2" x 2" sleepers embedded in concrete.
 - d Wood block floorings on concrete: Set blocks in mastic and install in accordance with flooring manufacturer's directions.

- C Ceramic Tile. See 307-C-5-f.
- 1 Materials. See Appendix A.
 - 2 Grade: Not less than Standard grade.
 - 3 Setting bed.
 - a Mix 1 part portland cement, 4 parts sand; or 1 part portland cement, 2 parts sand, and 4 parts pea-size aggregate.
 - b Minimum thickness: 1 1/4 inches, if re-inforced with wire mesh; 3 inches when installed below top of chamfered joists, with finish tile surface at least 1 1/2 inches above tops of joists.
 - 4 When applied over wood subfloor: Install asphalt saturated felt over sub-floor underneath the wire mesh.
- D Rubber Tile, Asphalt Tile, and Linoleum. See 307-C-5-e.
- 1 Do not apply rubber tile or linoleum on slabs resting on the ground. Asphalt tile may be used on slabs bearing on the ground provided the slab area where the tile are to be applied has first been covered with membrane waterproofing.
 - 2 Install according to manufacturer's instructions.
 - 3 Install over lining felt, approximately 1 pound per square yard, when applied over wood subflooring. See 307-C-5-c.
 - 4 Adhesive for flooring to be waterproof; type as recommended by manufacturer of the floor covering.

315 GARAGES

- A Attached and Built-in Garages.
- 1 Construction same as required for the dwelling.
 - 2 If door opening occurs between garage and dwelling: Provide 6-inch curb at the door or construct garage floor 6 inches lower than adjoining floor.
 - 3 Installation of house heating unit or other fuel burning appliance in garage space not permitted. Install partition between space containing house heating unit and garage space.
 - 4 Wood frame walls and doors common to dwelling and garage: Finish on garage side to be 1-hour fire-resistive construction. Where rooms occur over garage, ceiling and all walls shall be 1-hour fire-resistive construction. See Appendix A.
- B One-story Detached Garages.
- 1 Comply with construction requirements for 1-story dwellings with the following exceptions:
 - a Bottom of concrete footings of frame garages, unless supported on slab, not less than 18 inches below natural grade.
 - b Studs, maximum spacing 24 inches o.c. Doubling of studs not required on jambs of openings less than 3'5" wide.
 - c Sheathing and building paper may be omitted.
 - d Corner post may be two 2" x 4"s, or a 4" x 4".
 - e Top plate may be single, provided rafters occur over studs and plate at corners is lapped to provide tie.
 - f Rafter ties at eaves not less than 2" x 4"s, maximum spacing 6 feet o.c.
 - g Corner bracing is required, except where wood sheathing is used, and may be applied on the inside surface of studs.
 - h Flooring may be gravel. If concrete, see 304-K-5.

APPENDIX A. BUILDING MATERIALS STANDARDS

The following recognized standards shall serve as a guide in determining the acceptability and use of materials wherever in the Rules and Regulations Appendix A is referred to, provided the standards are not in conflict with specific requirements of the Rules.

Abbreviation and Name of Standard - Address

- A. C. I.American Concrete Institute,
7400 Second Boulevard, Detroit, Mich.
- A. I. S. C.American Institute of Steel Construction,
New York City
- A. S. T. M.American Society for Testing Materials,
206 South Broad Street, Philadelphia, Pa.
- F. S.Federal Specifications,
U. S. Department of Commerce,
Superintendent of Documents,
Washington, D. C.
- N. B. F. U.National Board of Fire Underwriters,
85 John Street, New York City
- N. L. M. A.National Lumber Mfrs. Association
1319 - 18th St. N. W. Washington, D. C.
- S. P. R.Simplified Practice Recommendations,
U. S. Department of Commerce
Superintendent of Documents,
Washington, D. C.
- U. L.Underwriters' Laboratories, Inc.
207 East Ohio Street, Chicago, Illinois

<u>Material</u>	<u>Standard and Specification Number or Volume</u>
Aggregates, concrete.	A.S.T.M.-C33-44
Aggregates, lightweight	A.S.T.M.-C130-42
Brick, Common	A.S.T.M.-C62-44
Brick, concrete	A.S.T.M.-C55-37
Brick, sand lime.	A.S.T.M.-C73-39
Brick, fire	F.S.-HH-B-671b. Class B-1a.
Building paper. See paper.	
Built-up roofs, materials for	U.L. Built-up Roof Coverings-41

Cast stone	A.C.I.-704-44
Cement, Keene's	A.S.T.M.-C61-40
Cement, portland.	A.S.T.M.-C150-44
Cement, prepared masonry (for mortar)	A.S.T.M.-C91-40
Concrete block, hollow load-bearing	A.S.T.M.-C90-44
Concrete block, Hollow non-load bearing	A.S.T.M.-C129-39
Concrete block, solid, load-bearing	A.S.T.M.-C145-40
Concrete construction, design and materials used in	A.C.I.-318-41
Copper, sheet	A.S.T.M.-B152-46T
Fiber board, insulating	F.S.-LLL-F-321b.
Fiber board, structural	F.S.-LLL-F-311
Fire Resistive Construction	N.B.F.U.-Bldg.Code-43 Appendix A
Fire-clay, plastic	F.S.-HH-R-191
Galvanized sheet metal. See Sheet Metal	
Glass block	N.B.F.U.Bldg.Code-43- Sec.807-Pages 122-3-4
Lath, gypsum	A.S.T.M.-C37-42
Lath, metal	F.S.-QQ-B-101c F.S.-UU-P-31
Lead, sheet	F.S.-QQ-L-201
Lime, quick	A.S.T.M.-C5-26
Lime, hydrated.	A.S.T.M.-C6-44
Lumber, stress-grade.	Nat. Design Spec. for Stress-Grade Lumber and Fastenings ---- N.L.M.A.-44 Wood Structural Design Data, Supplement #1- Working stresses for structural lumber-N.L.M.A.-41 Wood Structural Design Data, Supplement #3- Maximum spans for joists and rafters-N.L.M.A.-41
Metal roofing. See Copper, lead, tin, zinc.	
Mortar. See Cement, prepared masonry (for mortar).	
Paper, sheathing, waterproof.	F.S.-UU-P-536
Plaster, gypsum	A.S.T.M.-C28-40
Prepared masonry cement. See Cement	
Roofing felt, asphalt-saturated	A.S.T.M.-D226-44
Sheathing board, gypsum	A.S.T.M.-C79-42
Sheet metal, galvanized	A.S.T.M.-A93-27
Shingles, asbestos cement	F.S.-SS-S-291a F.S.-FF-N-101
Shingles, asphalt	A.S.T.M.-D225-44T
Shingles, slate	F.S.-SS-S-451
Slag	A.S.T.M.-C33-44
Steel-Design, fabrication and erection of structural steel for buildings	A.I.S.C.-46
Steel, reinforcing	A.S.T.M.-A15-39
Steel, structural	A.S.T.M.-A7-42

Tile, clay, for floor and walls (ceramic)	S.P.R.-R-61-44
Tile, drain	A.S.T.M.-C4-24
Tile, Load-bearing clay.	A.S.T.M.-C34-41
Tile, Non-load-bearing clay.	A.S.T.M.-C56-41
Tin, roofing (terne plate)	F.S.-QQ-T-201
Wall board, composition	F.S.-UU-W-101a
Wall board, gypsum	A.S.T.M.-C36-42
Wood siding, See Lumber	
Wire Fabric, galvanized	F.S.-QQ-B-101c
	F.S.-UU-P-31
Zinc	F.S.-QQ-Z-201a